

PUBLIC HEALTH DEPARTMENT

BUHANA, JHUNJHUNU, RAJASTHAN

DATE ...25/01/2025...

Ref. No. - 96

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team the "GANGA PUBLIC SCHOOL", Rayali - kuharwas, Buhana, Jhunjhunu, On date...12/1/2025... And found that the "GANGA PUBLIC SCHOOL", has providing safe drinking water Facility for the students and members staff of the institute and is maintaining the hygienic sanitation condition In school building & the campus as per the norms prescribed by the central /state/UT Govt.

WATER QUALITY REPORT


SOURCE

1. Direct bore well 2. Water Tank

ITEMS	QUALITY	REMARKS
Chloride	208 mg/l	Safe
Fluoride	0.8 mg/l	Safe
PH	7.2	Safe
Total hardness	240 mg/l	Safe.
Bacteria	Nil	Safe.

The PH value found is in the range of7.2.....Which is safe.

The above is valid for a period of one year

for 
सहायक अभियन्ता
वन रक्षा, अधि. विभाग
जयपुर, बुहाना (झुंझुनू)
फोन नं. 2544417

PHED, BUHANA, JHUNJHUNU